



**Environmental and Laboratory Services**  
 90 ½ West Blackwell St., Dover, New Jersey 07801  
 (973) 989-0010 P, (973) 989-0156 F

## Analytical Results

Date: January 9, 2017  
 Client: North Hudson Academy  
 Address: 4511 Liberty Ave  
 North Bergen, NJ 07047

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-1  
 Sample location: Bsmt. Girls Bathroom 1 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/04/17	17:25	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-2  
 Sample location: Bsmt. Girls Bathroom 1 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:24  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	20:47	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-3  
 Sample location: Bsmt. Girls Bathroom 2 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:26  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	20:54	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-4  
 Sample location: Bsmt. Girls Bathroom 2 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:27  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	21:06	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-5  
 Sample location: Bsmt. Girls Bathroom 3 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:29  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	21:19	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-6  
 Sample location: Bsmt. Girls Bathroom 3 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:30  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	21:25	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-7  
 Sample location: Bsmt. Boys Bathroom 1 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:37  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	10.5 ug/L	15 ug/L	01/03/17	21:32	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-8  
 Sample location: Bsmt. Boys Bathroom 1 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:38  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	21:39	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-9  
 Sample location: Bsmt. Boys Bathroom 2 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:40  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.98 ug/L	15 ug/L	01/03/17	21:45	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-10  
 Sample location: Bsmt. Boys Bathroom 2 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:41  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	21:52	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-11  
 Sample location: Bsmt. Boys Bathroom 3 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.61 ug/L	15 ug/L	01/03/17	21:58	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-12  
 Sample location: Bsmt. Boys Bathroom 3 Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:44  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	22:05	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-13  
 Sample location: Bsmt. Boys Bathroom Water Cooler  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:47  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	22:11	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-14  
 Sample location: Bsmt. Boys Bathroom Water Cooler  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:05  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead (1)	SM3113B	<2 ug/L	5 ug/L	01/03/17	22:23	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-15  
 Sample location: Bsmt. Hallway ASD Bathroom Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:54  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	22:54	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-16  
 Sample location: Bsmt. Hallway ASD Bathroom Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:56  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	22:59	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-17  
 Sample location: Bsmt. Hallway ASD A Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:58  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	23:05	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-18  
 Sample location: Bsmt. Hallway ASD A Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:59  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	23:11	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-19  
 Sample location: Bsmt. Hallway ASD B Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:02  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	23:18	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-20  
 Sample location: Bsmt. Hallway ASD B Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:03  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	23:24	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-21  
 Sample location: Bsmt. ASD Boiler Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:19  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	23:30	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-22  
 Sample location: Bsmt. ASD Boiler Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:20  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/03/17	23:35	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-23  
 Sample location: Bsmt. Kitchen Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:22  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/03/17	23:48	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-24  
 Sample location: Bsmt. Kitchen Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:23  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	00:00	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-25  
 Sample location: Bsmt. PSD Bathroom Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	3.85 ug/L	15 ug/L	01/04/17	00:06	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-26  
 Sample location: Bsmt. PSD Bathroom Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	00:12	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-29  
 Sample location: 1<sup>st</sup> Fl Grammar Sch. Utility Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:39  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	8.16 ug/L	15 ug/L	01/04/17	00:30	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-30  
 Sample location: 1<sup>st</sup> Fl Grammar Sch. Utility Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:40  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	00:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-31  
 Sample location: 1<sup>st</sup> Fl Room 103 Sink (Right Tap)  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:34  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	10.4 ug/L	15 ug/L	01/04/17	00:42	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-32  
 Sample location: 1<sup>st</sup> Fl Room 103 Sink (Right Tap)  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:35  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	00:48	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-33  
 Sample location: 2<sup>nd</sup> Fl High Sch. Utility Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:43  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	4.68 ug/L	15 ug/L	01/04/17	01:00	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-34  
 Sample location: 2<sup>nd</sup> Fl High Sch. Utility Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:44  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L /L	5 ug/L	01/04/17	01:30	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-35  
 Sample location: Field Blank  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 10:21  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/04/17	01:36	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-36  
 Sample location: Art Room Bsmt. Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:09  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/04/17	01:42	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-37  
 Sample location: Art Room Bsmt. Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:10  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	01:48	2 ug/L

Sample description: Drinking Water / 1<sup>st</sup> Draw / DWS4473-38  
 Sample location: Bsmt. Ceramics Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:14  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	15 ug/L	01/04/17	01:52	2 ug/L

Sample description: Drinking Water / Flushed / DWS4473-39  
 Sample location: Bsmt. Ceramics Room Sink  
 Sampled by: D. Diaz  
 Sample date: 12/28/16  
 Time: 11:15  
 Analyst: B. Moraga

Parameter	Method	Sample Result	NJDEP Limit	Date Analyzed	Time Analyzed	Reporting Limit
Lead	SM3113B	<2 ug/L	5 ug/L	01/04/17	02:00	2 ug/L

ug/L = micrograms per liter

All testing was done within the required holding time.

I certify that these samples were analyzed in accordance with procedures approved by the New Jersey Department of Environmental Protection.

Laurette Young (for SV)  
 Susan VanVeen, Lab Manager  
 NJ Laboratory Certification ID # 14013

January 12, 2017  
 Date